

**HMER.EX2604
Check Valves**[Page Bottom](#)

Check Valves[See General Information for Check Valves](#)**NIBCO INC**

EX2604

WORLD HEADQUARTERS
1516 MIDDLEBURY ST
PO BOX 1167
ELKHART, IN 46515 USA

Swing type, Model F-908-B, sizes 4, 6, 8, 12 in. with metal to metal checks; Model F-908-W, sizes 4, 6, 8, 12 in. with rubber-faced checks.

Swing type, Model FI908W, sizes 3, 4, 6, 8 in. with rubber faced checks having flanged ends.

Split clapper type, Model KW-900-W, sizes 2-1/2, 3, 4, 5, 6, 8, 10, 12 in. wafer style, with resilient seats. Installation-horizontal or vertical.

Model KG-900-W sizes 2-1/2, 3, 4, 5, 6, 8, 10, 12 in. with resilient seats, grooved style for working pressure of 250 psi.

Model KG900W350, sizes 2-1/2, 3, 4, 5, 6, 8, and 10 in., with resilient seats, grooved style for working pressure of 350 psi.

Last Updated on 2009-08-06

[Questions?](#)[Print this page](#)[Notice of Disclaimer](#)[Page Top](#)

[Copyright © 2010 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

